

STANDARD NOTES:

- 1. UNLESS OTHERWISE DIRECTED BY THE WPCA OR ITS TECHNICAL CONSULTANT, MINIMUM PITCH FOR 6" SERVICE LATERALS SHALL BE 14" PER FOOT.
- 2. PROPOSED LOCATIONS OF SERVICE LATERALS TO BE COORDINATED IN THE FIELD WITH THE WPCA OR ITS TECHNICAL CONSULTANT.
- 3. IF ROCK IS PRESENT, IT SHALL BE EXCAVATED AT LEAST 10—FEET BEYOND THE END OF THE STUB WITHIN THE RIGHT OF WAY OR SEWER EASEMENT.
- 4. REFER TO SECTION 02515 FOR ADDITIONAL REQUIREMENTS ASSOCIATED WITH GRAVITY SEWER SERVICES.
- 5. IF DIRECTED BY WPCA OR ITS TECHNICAL CONSULTANT, MARKER POST CAN BE LEFT 6" ABOVE FINISHED GRADE.

Water Pollution Control Authority Town of Canton

4 Market Street P.O. Box 168 Collinsville, Connecticut 06022 SEWER CONSTRUCTION DETAIL

GRAVITY SANITARY SEWER SERVICE LATERAL

NO SCALE

LATEST REVISION: 2/07

NO. 009