

**Addendum No. 2**

July 9, 2014

**Andrew Drive & High Valley Drive, Et.Al. – Incidental Roadwork**  
**Contract #2014-04**

Town of Canton, CT

This Addendum No. 2 makes the following modifications to Contract #2014-04 as follows:

- 1.) In item 6.) which is on Revised Page 84 of 100;

SDR 35 PVC perforated pipe [ASTM D3034] is considered an approved equal to PVC (Schedule 40) pipe [ASTM D-1785].

- 2.) In item 15.) which is on Revised Page 88 of 100, ignore [not part of item] the following words;

“provide a 3” compacted thickness two-course [1-1/2” Class 2 surface course on a 1-1/2” Class 1 binder course] permanent bituminous concrete pavement [with an emulsion tack coat on all cut surfaces and joints] on a 6” compacted thickness processed gravel base over the trench excavation.”

**The bid due date has remained unchanged.**

**THIS ENDS ADDENDUM NO. 2**